

7-22-03

DRI -

RE: SESKO PROPERTY

HERE IS A COPY OF
THE NOTICE OF CORRECTION

ISSUED BY OUR

UNDERGROUND STORAGE TANK
INSPECTOR.

DICK WALKER

The Department of Ecology
Washington
with the
accomplish

Storage Tank Program

RECEIVED
JUL 23 2003

BREMERTON
BUILDING DEPARTMENT

Notice of Non-Compliance

laws that protect human health and the
violations of Chapter 173-360 of the
statutes, which are listed below. Along
with the dates by which they must be

tank site at 1801
locations of Chapter

remove tanks and
360-385, WA

majorly ICBG/IFCI)
used to accomplish
L (WAC 173-360-375)

appropriate Action to
Contamination (WAC 173-360-375)

If you cannot complete the required corrections by the date(s) included, please submit a written request for an extension to the Ecology contact person listed below by _____. To be considered for an extension please include the following information: Reason the extension is needed, projected completion date(s), any steps already taken, and a description of the work remaining to be completed. You will be notified if an extension can be granted.

If you require assistance in accomplishing the requirements, please contact the Ecology personnel listed below.

Department of Ecology Contact

On-Site Contact Information

Name Norman Stewart
Region Northwest
Phone (425) 649-7114
Fax _____
Signature [Signature]
Date/Time 11:00 AM 7/16/03

On-Site Contact Bill Sesko
Title Owner
Site Address _____
Phone 360 377 0697
Signature [Signature]

- ☒ Photos Taken ☐ Notice of Penalty Issued ☒ Tech. Assist. Materials Provided
☒ Ecology Enforcement Authority Explained ☒ Copy of Notice Given to Site Contact

Ecology is an Equal Opportunity employer. If you have special accommodation needs, contact the Ecology regional office for your county.



Toxics Cleanup / Underground Storage Tank Program

Site Number _____

RECEIVED
JUL 23 2003

BREMERTON
BUILDING DEPARTMENT

☐ Technical Assistance Visit

☒ Notice of Non-Compliance

The Department of Ecology is responsible for overseeing environmental laws that protect human health and the environment in Washington State. During this visit, Ecology observed violations of Chapter 173-360 of the Washington Administrative Code, the Underground Storage Tank Regulations, which are listed below. Along with the violations are the steps required to correct the violations and the dates by which they must be accomplished.

During ~~the~~ an inspection of the tank site at 1801
Pennsylvania Ave the following violations of Chapter
173-360 were noted:

① No 30 day Notice of intent to remove tanks was
filed with Ecology. WAC 173-360-385, WA

② International Code Council (formerly ICBO/IFCI)
Certified Supervisors were not used to accomplish
Tank removal (WAC 173-360-600). (WAC 173-360-385)

③ Tank owner Failed to take appropriate Action to
report possible spills and/or contamination (WAC 173-360-
385)

If you cannot complete the required corrections by the date(s) included, please submit a written request for an extension to the Ecology contact person listed below by _____. To be considered for an extension please include the following information: Reason the extension is needed, projected completion date(s), any steps already taken, and a description of the work remaining to be completed. You will be notified if an extension can be granted.

If you require assistance in accomplishing the requirements, please contact the Ecology personnel listed below.

Department of Ecology Contact

Name Norman Stewart
Region Northwest
Phone (425) 649-7114
Fax _____
Signature [Signature]
Date/Time 11:00 AM 7/16/03

On-Site Contact Information

On-Site Contact Bill Sosko
Title Owner
Site Address _____
Phone 360 377 0697
Signature [Signature]

☒ Photos Taken ☐ Notice of Penalty Issued ☒ Tech. Assist. Materials Provided
☒ Ecology Enforcement Authority Explained ☒ Copy of Notice Given to Site Contact

Ecology is an Equal Opportunity employer. If you have special accommodation needs, contact the Ecology regional office for your county.

To correct these violations, Please take the following actions:

- ① Obtain the Services of an International Code Council (ICC) certified Technician to properly ~~close~~ close the Rimmer tank.
- ② Mitigate any associated contamination as agreed with in the overall site cleanup plan as determined by the Toxics Cleanup Program with the Department of Ecology.

Please ~~take the~~ begin the Tank removal process no later than August 15, 2003. File appropriate Closure information with Ecology within 30 days of tank closure.

Inspector:

[Signature]

Date:

7/16/03

Tank Owner:

[Signature]

Date:

JULY 16, 03

Ecology is an Equal Opportunity employer. If you have special accommodation needs, contact the Ecology regional office for your county.